

Project: Synthetic Turf Installation Services West Thames Lawn **Date:** 9/4/15

RE: Addendum # 4
of Pages: (1 page)

The following clarifications shall apply to the Battery Park City Authority Request for Proposals for “Synthetic Turf Installation Services West Thames Lawn.”

Clarifications:

1. The original due date for the Synthetic Turf Installation Services West Thames was September 9, 2015 at 5:00 pm. As per this addendum, the due date is changed to **September 14, 2015 at 3:00 pm.**
2. The pre award interview schedule indicated in addendum #1 has been changed. Interviews will NOT be held on September 14, 2015. As per this addendum, the interviews will be held on **September 16, 2015 between the hours of 9:00am and 2:00pm.** Proposers should therefore be prepared to make themselves available at a time selected by BPCA within that five hour window if selected for an interview.
3. The Bid documents included in the Request for Proposal indicate that, as part of Add Alternate #1, detail #2, the proposed water line must be located 2 feet 6 inches below grade. As per this addendum, a depth of 18 inches below grade is adequate.
4. The Bid documents included in the Request for Proposal indicate that construction access to the site is recommended via the RT-9A Walkway. As per this addendum, the contractor may propose an alternative access path. Any proposed construction access paths must consider and maintain protected pedestrian access in both the North/South and East/West directions adjacent to the site.

By signing the line below, I am acknowledging that all pages of this addendum have been received, reviewed and understood, and will be incorporated into the bid price submitted. This document must be attached to the Proposal for consideration.

Print Name

Signature

Date

Number of pages received: _____ <fill in>